

Schedule 4

Quantities of hazardous substances that require fire extinguishers

rr 5.2, 5.3

Class 2 – 5 only showing as we do not certify class 1 substances.

Hazard classification	Description	Quantity	No
2.1.1A	Non-permanent gas	50 kg	1
	Permanent gas	30 m3	1
2.1.1B	Non-permanent gas	200 kg	2
	Permanent gas	120 m3	2
2.1.2A	Aerosol	3 000 L aggregate water capacity	1
3.1A	Liquid	50 L	1
		200 L	2
3.1B	Liquid	250 L	2
3.1C, 3.1D	Liquid	500 L	2
3.2A, 3.2B, 3.2C	Liquid	50 L	1
		200 L	2
4.1.1A	Solid	250 kg	2
4.1.1B	Solid	500 kg	2
4.1.2A, 4.1.2B, 4.1.2C, 4.1.2D, 4.1.2E, 4.1.2F, 4.1.2G	Liquid	50 L	1
		200 L	2
	Solid	50 kg	1
		200 kg	2
4.1.3A, 4.1.3B, 4.1.3C	Solid	50 kg	1
		200 kg	2
4.2A	Liquid	50 L	1
		200 L	2
	Solid	50 kg	1
		200 kg	2
4.2B	Liquid	250 L	2
	Solid	250 kg	2
4.2C	Liquid	500 L	2
	Solid	500 kg	2
4.3A	Liquid	50 L	1
		200 L	2
	Solid	50 kg	1
		200 kg	2
4.3B	Liquid	250 L	2
	Solid	250 kg	2
4.3C	Liquid	500 L	2
	Solid	500 kg	2
5.1.1A	Liquid	5 L	1
	Liquid	25 L	2
	Solid	5 kg	1
	Solid	25 kg	2
5.1.1B	Liquid	200 L	1
	Liquid	500 L	2
	Solid	200 kg	1
	Solid	500 kg	2
5.1.1C	Liquid	500 L	2
	Solid	500 kg	2
5.1.2A	Non-permanent gas	10 kg	1
		50 kg	2
	Permanent gas	10 m3	1
		50 m3	2
5.2A, 5.2B	Liquid	1 L	1
	Solid	1 kg	1
5.2C, 5.2D	Liquid	10 L	1
	Solid	10 kg	1
5.2E, 5.2F	Liquid	50 L	1
	Solid	50 kg	1